

## RESOLUTION

### AMENDMENT TO THE REGULATIONS GOVERNING UTILITY SERVICE -

#### USE OF PUBLIC FIRE HYDRANTS

WHEREAS, the James City Service Authority (JCSA) proposes to amend the Regulations Governing Utility Service in order to strengthen procedures for withdrawing water from public fire hydrants for development purposes.

NOW, THEREFORE, BE IT RESOLVED that the Board of Directors of the James City Service Authority, James City County, Virginia, hereby adopts changes to Section 21, Regulations Governing Utility Service, which are summarized below to become effective October 26, 2004:

##### Self-Supplied Metering Device

- Hydrant meters must have approved backflow devices that are tested annually.
- Hydrant meters are permitted for a six-month term for a specific job site.
- Hydrant meter device must display a JCSA placard to identify the device has been approved.

##### JCSA Furnished Hydrant Device

- Permittee is to pay a deposit prior to receiving hydrant meter.
- Hydrant meters are issued for 30-day terms with three renewals.
- Hydrant meter must display a JCSA placard indicating the meter is approved at all times.
- Meters that are retained past due date will be assessed \$20 per day.

##### Water Withdrawal Locations

- Establishes four locations in the County to withdraw from hydrants:
  - 1) JCSA Operations Center - Tewning Road
  - 2) Toano Fire Station
  - 3) Law Enforcement Center
  - 4) Entrance to Stonehouse Development
- Allows for special exemptions on a case-by-case basis.

BE IT FURTHER RESOLVED, that the complete proposed amendments be made part of this resolution.



John J. McGlennon  
Chairman, Board of Directors

<u>DIRECTOR</u>	<u>VOTE</u>
-----------------	-------------

HARRISON	AYE
GOODSON	AYE
BROWN	AYE
BRADSHAW	AYE
MCGLENNON	AYE

ATTEST:



Sanford B. Wanner  
Secretary to the Board

Adopted by the Board of Directors of the James City Service Authority, James City County, Virginia, this 22nd day of February, 2005.

firehydrants05.res