

ADDENDUM NUMBER 1
October 14, 2009

JAMES CITY COUNTY
INVITATION FOR BID 10-3797
James City/Williamsburg Community Center Parking Lot Asphalt Repairs

This Addendum is forwarded to provide answers to prospective bidders' questions concerning the Invitation For Bid documents, and include the Pre-Bid Log. Please contact Kitty Hall, Buyer I, FAX (757) 253-6753/Tel (757) 253-6646, email: khall@james-city.va.us if you have any questions about this Addendum.

Question:

- 1.) Can you (James City County) clarify if the entire parking lot will need to be milled and the old asphalt removed?

Answer: No, the base material and the asphalt already in place will be left, and 2" of new asphalt put on top of the existing material. Milling will only need to be done as is standard, 18" to concrete swell, to assure proper slope and drainage

- 2.) How does the county want to address the large catch basins? If new asphalt is put on top of the existing and milled to the concrete, the degree will potentially be too great.

Answer: The county would like the old asphalt around the catch basins removed and new asphalt installed and milled per standard to the concrete catch basin, to achieve a proper slope and good drainage.

- 3.) Will any areas need to be saw-cut?

Answer: If any areas need additional work, they should be brought to the attention of Craig Nordeman, Project Manager and if approved, will be taken care of with a change order.

- 4.) During the pre-bid, the county said that they wanted 2" loose depth asphalt compacted to 1 ½" depth. In the bid package it calls for 2" depth asphalt, which usually refers to the compacted depth of the asphalt. Please clarify.

Answer: It should be "2" depth asphalt"- referring to the finished compacted depth of the asphalt.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

PRE-BID CONFERENCE/SITE VISIT

INVITATION FOR BID 10-3797

TITLE: James City/Williamsburg Community Center Parking Lot Asphalt Repairs

October 14, 2009

COMPANY NAME & ADDRESS	CONTACT NUMBERS
Walter C. Via P.O. Box 592 West Point Va 23181	PH: 804-785-2288 FAX: 804-785-2914 E-MAIL: Steven@wcvia.com
Representative: Steven Whittaker	
R W MULLER CONT 491 MULLER LANE NN VA 23606	PH: 757 249 0500 FAX: 757 249 1655 E-MAIL: leon@ewmuller.com
Representative: LEON JOYCE	
REMAC Inc. P.O. Box 9 Freeman, U.A. 27856	PH: 434-634-2111 FAX: 434-634-0024 E-MAIL: WWW.REMAC.US.COM
Representative:	
Parking Lot Maintenance, Inc. P.O. Box 5296 Williamsburg, VA 23188	PH: 876-2520 FAX: 564-4506 E-MAIL: plm@parkinglotmaintenance.com
Representative: Brett Kyle	
Shouse - Manager Williamsburg VA 899-8772	PH: FAX: E-MAIL:
Representative: Robert Combs	
Pacific Construction Co 588 Oyster Point Rd. Newport News, VA 23602	PH: FAX: E-MAIL:
Representative: Lisa Johnson	
Pembroke Construction Co INC 802 W Pembroke Ave HAMPTON VA 23669	PH: 723.2591 FAX: 723.8895 E-MAIL: abrockington@pembroke
Representative: DONN BROCKINGTON	abrockington@pembroke construction.com

PRE-BID CONFERENCE/SITE VISIT

INVITATION FOR BID 10-3797

TITLE: James City/Williamsburg Community Center Parking Lot Asphalt Repairs

October 14, 2009

COMPANY NAME & ADDRESS	CONTACT NUMBERS
Peninsula Paving Inc	PH: 757-247-5908
810 Plum Ave	FAX: 757-247-5909
Hampton VA 23661	E-MAIL: andy.lerner1@gmail.com
Representative: Andy Lerner	
James City - Purchasing	PH: 757-2536646
101-F York & Bay Rd #300	FAX: 757-2536753
Wnbg VA 23185	E-MAIL: khall@james-city.va.us
Representative: Kitty Hau	
Jcc General Services	PH: 259-4080
Towning Rd	FAX:
Wnbg VA 23188	E-MAIL:
Representative: Craig Hodson	
	PH:
	FAX:
	E-MAIL:
Representative:	
	PH:
	FAX:
	E-MAIL:
Representative:	
	PH:
	FAX:
	E-MAIL:
Representative:	
	PH:
	FAX:
	E-MAIL:
Representative:	