

DATE: January 24, 2012

ADDENDUM NO.3

**WILLIAMSBURG-JAMES CITY COUNTY PUBLIC SCHOOLS
INVITATION FOR BIDS 12-0020
Modular Educational Classroom Trailers-Berkeley and Hornsby Middle Schools**

This Addendum is issued to answer bidder questions. Please contact Kitty Hall, Purchasing Director, email: khall@james-city.va.us if you have any questions.

Question: Are Commercial Room Ventilators Required for these Classrooms? (See below basis of re-questioning this requirement)

Basis for Questions: Please provide the maximum person “student” count per each 24’ x 30’ classroom – the number of occupancies that each classroom will serve determines the ASHRAE requirements for commercial room ventilators “CRV”. Commercial Room Ventilators increase the amount of fresh air “outside air” brought into the system. the increase of fresh air increases the number of allowable occupancies in the space. Standard HAVC units will allow 18 person per classroom (Total 36 persons) per each 24’ x 60’ Classroom. HVAC units w/ CRV will allow 36 person per classroom (Total of 72 persons) per each 24’ x 60’ Classroom

ANSWER: (Standard HVAC units will allow 18 person per classroom (Total 36 persons) per each 24’ x 60’ Classroom.)

This Addendum 3 is incorporated into the Bid Documents and will be made part of the resulting contract.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.